

End-Use Testing at BPA

2015 NERC-DOE FIDVR Workshop

Presented by


Dmitry Kosterev and Steve Yang, BPA

BPA End-Use Testing Lab



<< Temperature controlled chamber

Controllable power supply >>



Measurement System >>

Residential Air-Conditioner Tests

BPA, SCE and EPRI tested independently a number of single phase air-conditioners

Tests included voltage sags, ramps, oscillations, as well as frequency excursions




Learned in the first round:


- Residential air-conditioners stall for a sudden drop in voltage to 50%-60% of nominal in less than 3 electrical cycles
- Once stalled, residential air-conditioner remain stalled even when the voltage is recovered, until coolant pressure is equalized
- Thermal protection trips in 5 to 30 seconds

Test Findings: Compressor Motor Steady-State Loading


- Compressor loading and stall voltage depend on the ambient temperature
- Compressor motors have high power factor ~ 0.97 when running



(a) Torque-Speed Curves



1 phase supply, 2 winding,
capacitor-run motor




- Three phase motor elec. torque
- Single phase motor elec. torque
- Load torque

(b) Compressor Motors Inertia is Very Low


$H = 0.03 - 0.05$ seconds

E.g. 3.5-ton compressor motor:

Weight: 4.6 kg




(c) Compressor Load Torque in very cyclical




It is very possible that the motor stalls at the next compression cycle⁷



Compressor Motor Tests – Power-Voltage Trajectories



* note motor load and stall voltage increase with temperature



“Performance” Model



Motors stall when voltage drops below V_{stall} for duration T_{stall}

A fraction F_{rst} of the aggregated motor can restart when the voltage exceeds V_{rst} for duration T_{rst}

System Studies

Studies done with developed AC models were much more conservative compared to actual experience: the model indicated greater and wider FIDVR phenomenon compared to actual experiences


...Back to the drawing board...

Testing and Modeling – Round 2


BPA, John Undrill and Bernie Lesieutre found a “common mode failure” mode in SCE-BPA-EPRI testing - **all voltage sags were sudden and applied at voltage waveform zero-crossing**

Additional testing done at BPA in collaboration with John Undrill and Bernie Lesieutre showed that **air conditioners tend to be less prone to stalling when the fault is applied at the waveform peak, or voltage is ramped down** instead of sudden steps down

AC Stall, Instantaneous Voltage Dip




AC Stall, : 1 Cycle Ramp in Voltage Dip



Next Steps

1. Update AC “performance” model



2. Add dynamic MOTORC model to composite load model

3. Continue benchmarking positive sequence models (GE PSLF and PSS[®]E) with point on wave models (PSCAD)

Thank You